



<input checked="" type="checkbox"/>	AMENDMENT OF SOLICITATION
<input type="checkbox"/>	MODIFICATION OF CONTRACT

City of New Braunfels
Purchasing
551 Landa Street
New Braunfels, Texas 78130

1. Solicitation No. CSP 23-003 County Line Road Improvements	2. Contract No.	3a. Addendum No. 2 3b. Modification No.	4. Effective Date of this Action 11/30/2022
5. Name and Address of Offeror or Contractor	6. For Information Call: (No collect calls or Fax offers accepted) Purchasing: Barbara Coleman Phone No.: 830-221-4389 Fax No.: 830-608-2112		7. Amount of Contract/Order is: Increased by: Decreased by: New Total: <input type="checkbox"/> Unchanged

8. THIS BLOCK APPLIES TO AMENDMENTS OF SOLICITATIONS ONLY:

The above numbered solicitation is amended as set forth in Block 10 below.

The date and time specified for receipt of offers IS NOT extended.

THE DATE AND TIME SPECIFIED FOR RECEIPT OF OFFERS IS CHANGED TO: DECEMBER 7, 2022

Offerors must acknowledge receipt of this amendment prior to the date and time specified in the solicitation or as amended, by one of the following methods:

- (i) By completing Blocks 5 and 11 and returning this Addendum in the number of copies specified for the solicitation;
- (ii) By acknowledging receipt of this Addendum on each copy of the bid submitted; or,
- (iii) By separate letter, telegram, or fax referencing the solicitation and addendum.

If by virtue of this Addendum offeror desires to change an offer already submitted, such change may be made by letter, telegram, or fax, provided each such notice makes reference to the solicitation AND this Addendum, and is received prior to the date and time specified.

NOTICE: NON-RECEIPT OF YOUR OFFER AND THIS ADDENDUM AT THE DESIGNATED PLACE WITHIN THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.

9. THIS BLOCK APPLIES TO MODIFICATIONS TO CONTRACTS, DELIVERY OR PURCHASE ORDERS ONLY.

The above numbered Contract, Delivery, or Purchase order is modified as set forth in block 10 below.

This Change Order is issued in accordance with authority granted by instrument referenced in block 2.
 The instrument in Block 2 is modified to reflect administrative changes.
 This Supplemental Agreement is entered into pursuant to the Authority of:
 Other (Specify type of modification and authority): _____.
 CONTRACTOR IS REQUIRED TO SIGN THIS DOCUMENT AND RETURN ONE ORIGINAL.
 Contractor is not required to sign this document but is requested to acknowledge receipt.

10. DESCRIPTION OF CHANGES

This Addendum No. 2 provides the answers to questions received after the pre-proposal meeting and by the question deadline or those that were not answered.

Except as provided herein, all terms and conditions of the document referenced above remain unchanged and in full force and effect.

11a. SIGNATURE OF OFFEROR OR CONTRACTOR		CITY OF NEW BRAUNFELS, TEXAS	
		<i>"Barbara Coleman"</i>	
11b. PRINTED NAME AND TITLE	11c. DATE	11/30/2022	Date
		Barbara Coleman Purchasing Manager	

Addendum 2

CSP 23-003 – County Line Road Improvements

November 30, 2022

13. I understand RAP is not allowed in the TY D hot mix design. Can a TxDot approved TY B design with Rap be used in the TY B PG64-22 hot mix item. This item is being used for full depth flex base repair at two locations per the plans.
We are ok with RAP in the Type B black base.
14. After close inspection of the subject roadway, it appears on the numerous sections there is obvious distress with rutting and heaving that a 3" mill and fill will clearly not address.
Contrary, the reconstruction section (2+00 – 10+26) does have areas that should be addressed, but it appears portions of pavement are in better condition than other sections further east.
What was the methodology utilized to address the pavement rehabilitation?
For bidding purposes, the contractor shall bid as indicated in the bidding documents. The City will evaluate any proposed modifications after an executed contract is in place.
15. This is a suburban roadway with subdivisions and schools adjacent, why is there a one course surface treatment on the surface course?
For bidding purposes, the contractor shall bid as indicated in the bidding documents. The City will evaluate any proposed modifications after an executed contract is in place.
16. What are What are the work hours outside of the school zones as cited in the plans?
Outside of School Zone, hours are 8-5.
17. There is a sequence on page 7 of plans. If the contractor adheres to Plan sequence, utilizing MUTCD requirements will this suffice be ample for TCP?
Yes. This will suffice as a submitted traffic control plan. Any changes/deviations from this phasing plan on Page 7, will need to be reflected in a resubmitted TCP.
18. Is there a max lift thickness for Base and HMA?
Please see TXDOT Item 247 (Flexible Base) and TXDOT Item 341 (Dense-Graded Hot-Mix Asphalt) for maximum lift thicknesses.
19. Several schools in area. Is contractor going to be restricted to 9AM to 2PM work hours?
Yes, contractor will be restricted to these hours in the school zone/school area. Will be coordinating with the school and City Inspector and Project Manager.
20. Is seal coat going to be placed on top of TYD SACP 70-22 surface mix?
Please see sheets 26-27 of the plans for Typical Sections.
21. What are asphalt and aggregate rates for asphalt and aggregate for seal coat?
The Binder rate shall be 0.36 gal/SY and the aggregate spread rate shall be 144 SY/CY for the Seal Coat.

Addendum 2

CSP 23-003 – County Line Road Improvements

November 30, 2022

22. Mill item is for 3" – 4"; typ shows mill 3" place 3"; existing says 4" HMA. Will there be 1" +/- HMA left in place after mill or does all HMA get removed?

Contractor shall mill 3" where designated in the plans, utilizing full depth milling in areas that require additional corrective measures as defined in the plans.

23. Will any allowance (bid item) be added to hire police to help in traffic control due to schools in vicinity?

A bid item will not be added. Contractors Base Bid Item 21 (Barricades, Signs, and Traffic Handling) shall be inclusive of all traffic control items within the Contractor's TCP plan. Additional items shall be at Contractor's expense.

24. Can we obtain CAD files from the Engineer for this project that includes Line work, existing and proposed contours? Our use is specifically for area and volume quantity take-off. If required we will sign disclaimers, prior to receiving.

After contract is awarded CAD files will be made available to the awarded contractor.

25. Bid item 33 Work Zone Pavement Markings is a LS item. I cannot find what is being required in the plans in order to quantify. Can more information be provided for this LS bid item?

This item is intended to include the necessary pavement markings to support the contractor submitted traffic control plan.